



esp

Environmental &
Safety Professionals

A division of Enviro-Net Australia Pty. Ltd.
ABN 39 067 499 389 ACN 067 499 389 NATA Reg. 3110
Unit 2, 2B Parker Street, Footscray, Victoria 3011
Ph: (03) 9688 8000 Fax: (03) 9689 6470
Email: esp@esplabs.com.au
www.environet.com.au

Melbourne
Sydney
Newcastle

ASBESTOS IDENTIFICATION REPORT

DATE: 30TH JANUARY 2014

ESP JOB NUMBER: 21772L

NAME: ROSCON PROPERTY SERVICES

ADDRESS: 150 SYDNEY ROAD, COBURG
VIC 3058

SAMPLED FROM: AS RECEIVED (JOB NUMBER: 6168)

SAMPLED BY: AS RECEIVED

DATE RECEIVED: 24TH JANUARY 2014

TEST METHOD: Qualitative identification of asbestos types in bulk samples by polarised light microscopy, including dispersion staining, using ESP in-house Method No. 2 and methodology in accordance with AS4964.

LAB NUMBER	SAMPLE DESCRIPTION	RESULT
E31328	1: ATRIUM WALL – FIBRO CEMENT MATERIAL (20 x 20 x 3 mm)	NO ASBESTOS DETECTED ¹
E31329	2: DIVIDING FENCE PANEL – FIBRO CEMENT MATERIAL (40 x 20 x 3 mm)	NO ASBESTOS DETECTED ¹

The results contained in this report relate only to the sample(s) submitted for testing. ESP Environmental & Safety Professionals accepts no responsibilities for the representivity of the sample(s) submitted.

¹ Organic fibre(s) detected.




WORLD RECOGNISED
ACCREDITATION

NATA Accredited Laboratory

Number: 3110

Accredited for compliance with ISO/IEC 17025


Tanmay Kshatriya
Approved Identifier


Tanmay Kshatriya
Approved Signatory